



CITY COUNCIL AGENDA REPORT



DEPARTMENT: Public Works

MEETING DATE: January 16, 2007

PREPARED BY: David Fike, Director of Public Works

AGENDA LOCATION: AR-1

TITLE: Steel Tank Interior Coating for the Reservoir No.2, Project No. C-2982; Award of Contract to J. Colon Coatings, Inc., in the Amount of \$137,120.00

OBJECTIVE: To award a contract to J. Colon Coatings, Inc. for Reservoir No.2, Steel Tank Interior Coating.

BACKGROUND: Reservoir No. 2 is an above ground steel tank water reservoir located at 2655 South Myrtle Avenue, the City's Well Field site. The tank has a capacity of 1.2 million gallons.

As part of our routine water tank maintenance, the City's water reservoirs are inspected every 3 years. The last inspection was in August 2005 and it was determined at that time that Reservoir Tank No. 2 internal coating was in need of repainting, and that the exterior paint of the tank is in good condition and does not need repainting. The Engineer's Estimate for this project is calculated at \$138,000.00.

ANALYSIS: On December 13, 2006 two (2) bids were received and opened by the City Clerk, they are as follows:

J. Colon Coatings, Inc.	\$137,120.00
CB & I Constructors, Inc.	\$174,600.00

Staff has reviewed the bids and found that all documents to be in order. References from La Crescenta Water District and Laguna Niguel Water were contacted and found that the contract had performed similar work in a satisfactory and timely manner.

FISCAL IMPACT: Funds are available in the Water Fund.

RECOMMENDATION: Staff recommends an award of contract to J. Colon Coatings, Inc. (6047 Carol Avenue, Alta Loma, CA 91701) in the amount of \$137,120.00 for the Forebay No.2, Steel Tank Interior Coating project; and reject all other bids.

COUNCIL ACTION REQUIRED: If the Council concurs, the appropriate action would be a Motion to:

Award a contract to J. Colon Coatings, Inc. in the amount of \$137,120.00 for Reservoir No.2, Steel Tank Interior Coating project; and

Reject all other bids.

AR-1